



EC TYPE-EXAMINATION CERTIFICATE VARIATION

CERTIFICATE NUMBER Sira 04ATEX2010 **Dated** 15 September 2005

VARIATION NUMBER 2 (TWO) **Dated** 15 September 2005

VARIATION TO EQUIPMENT

To permit:

- 1 The electrical parameters of the 4-20mA output to be changed as follows; the parameters of the other pins remain unchanged:

Pin	Ref	Ui	Ii	Pi	Ci	Li
3	4-20mA IN	30 V	162mA	1.0W	0	0
4	4-20mA OUT					

- 2 The option to reduce the number of infra red (IR) sensors in the detector to one thus forming a Single IR detector model no. 20/20MR-XX-X-C.
- 3 The introduction of changes that affect non-safety critical components.
- 4 The introduction of minor drawing detail changes.
- 5 The recognition of a new model reference type 20/20MR-XX-X-C.

DESCRIPTIVE DOCUMENTS

Drawing No.	Sheet	Rev.	Date	Title
787831	1 of 1	A	15 Sep 05 (Sira stamp)	Label

ADDITIONAL CONDITIONS OF CERTIFICATION

None

File No. 52A11392

Report No. R52A11392A

This Variation and its schedules may only be reproduced in its entirety and without change

C Ellaby
Certification Officer